

**AMENDMENT NO. 01 APPROVED ON 1998-06-11 TO SLS 948 : PART 1 : 1991**

**SRI LANKA STANDARD SPECIFICATION FOR THREE-PIN PLUGS,  
SOCKET-OUTLETS AND SOCKET-OUTLET ADAPTORS**

**1. Clause 9.6 current breaking capability**

Delete the contents of Clause 9.6 and substitute with the following:

**9.6.1** Plugs and socket-outlets shall be capable of breaking current 125 per cent of the rated current at a voltage not less than 110 per cent of the rated voltage, 10 times in succession, at intervals of 30 seconds, the plug being withdrawn from the socket-outlet by hand at the rate of approximately 15 cm per second. The earthing socket-contact and neutral –contact shall be connected together, and the socket-outlet shall be mounted as it is normally done in service.

**9.6.2** After completion of the test, the voltage drop across the plug and socket-outlet shall not exceed 50 millivolts.

**2. Clause 10.1 Type tests**

Delete (f) of Clause 10.1 and substitute with the following:

(f) Current breaking capability (9.6);