

**AMENDMENT NO. 2 APPROVED ON 2006-11-29
TO SLS 948 : PART 3 : 1991**

**SRI LANKA STANDARD SPECIFICATION FOR THREE-PIN PLUGS,
SOCKET-OUTLETS AND SOCKET-OUTLET ADAPTORS**

PART 3 : SWITCHED SOCKET-OUTLETS

Clause 4.6

Delete this clause entirely

Clause 11

Delete this clause entirely

Clause 4.11

Delete the text of the existing clause including amendment no. 1 and substitute with the following :

Disconnect the pilot lights for the purpose of this test. The following additional requirements shall apply. See clause **9.6** of **SLS 948 : Part 1 : 1991**.

- a) For socket contacts as described in clause **9.6** of **SLS 948 : Part 1 : 1991**
 - b) For switch contacts with the switched socket-outlet plates in position and with all metal parts not in contact with live contacts connected to the earthed pole of the test circuit. The switch shall make and break the specified current in a substantially non-inductive a.c. circuit ten times in succession at intervals of 30 seconds. After the tests the switched socket-outlet shall be in a serviceable condition.
-