

**AMENDMENT NO. 2 APPROVED ON 2008-08-28
TO SLS 1206 : 2000**

Clause 4.2

Delete the existing text and substitute with the following.

4.2.1 trunking for medium mechanical stresses

4.2.2 trunking for heavy mechanical stresses

Clause 5.3

Delete the contents immediately after the title and substitute with the following:

The nominal external dimensions (i.e. the width and the height), in millimetres, of rectilinear cable trunking shall be selected from any of the following numbers.

10.0, 12.5, 14.0, 16.0, 20.0, 25.0, 32.0, 37.5, 40.0, 50.0, 75.0, 100, 150.

Clause 6

Incorporate the following immediately after the title as the first paragraph:

The manufacturer shall state the internal usable area for cables in mm² for the trunking.

Clause 7.3

Delete the existing table and substitute with the following :

Table 2 – Impact test data

Mechanical classification of trunking (1)	Impact energy J (2)	Mass of height Kg (3)	Fall height mm (4)
Medium	2.0	2.0	100 ± 1
Heavy	6.0	2.0	300 ± 1
