

AMENDMENT No.01 approved on 2019- 06-12 to NA to SLS EN 1992-1-1: 2013

SRI LANKA NATIONAL ANNEX TO EUROCODE 2: DESIGN OF CONCRETE STRUCTURES —PART 1-1: GENERAL RULES AND RULES FOR BUILDINGS

Page 13

TABLE NA.1 — Sri Lanka decisions for Nationally Determined Parameters described in SLS EN 1992

Delete the entire row of sub-clause **9.6.2** (1) and substitute the following row.

Sub-clause	Nationally Determined Parameter	Euro code recommendation	Sri Lanka decision
9.6.2 (1)	Minimum and maximum area of vertical reinforcement in walls	$A_{s,vmin} = 0.002A_c$ $A_{s,vmax} = 0.04A_c$ outside lap locations unless it can be shown that the integrity of the concrete is not affected and that the full strength is achieved at the ULS. This limit may be doubled at laps.	Use the Euro code recommendation