

Amendment No. 1 Approved on 2019-05-08 to SLS 734: Part 2: 2017

SRI LANKA STANDARD SPECIFICATION FOR 13 A PLUGS, SOCKET-OUTLETS, ADAPTORS AND CONNECTION UNITS PART 2: SPECIFICATION FOR 13 A SWITCHED AND UNSWITCHED SOCKET- OUTLETS (Second Revision)

1) Replace the existing Table 1 with the following Table including new Note 2)

Sequence	Sample	Test	Clause No
(1)	(2)	(3)	(4)
1	3	Inspection, measurement, gauging and manipulation.	5, 6, 7, 9.1, 11.1,(except 11.10), 9.2, 9.4, 10.1,12.1, 12.2, 12.3, 12.9, 12.10, 12.12, 12.14, 12.15, 12.16, 12.17, 12.18, 12.20,12.21,**12.25, 18.2, 18.3, 18.4, 18.6, 8 (except Annex C), 20
2	3	General	5, 9.3, 20.3 (10.2, 10.3 only), 18.1, 13.2, 12.13,(9.1.1 only), 12.4.1a), 12.4.1b), 12.5, 12.6
3	3		5, 12.13 (19.1.2 only), 16, 12.11 (12.11.1 only), 15, 18.5
4	3		5, 13.1, 14, 17.1.2 (9.1, 15, 12.19, 14, 12.4.1a), 10.2,12.6,12.7,12.8)
5	3		5, 13.2, 17.1.3, 19
6	3		5, 21
7	3	Materials	5, 22.2, 8.2 (Annex C only)
8	3		5, 23
9*	3	Positive break	5, 12.11.2
10	3	Ingress protection	5, 12.22, 12.23, 12.24
11	3	Electric vehicle charging	5, 13.1, 16.2, 17.2
12	3		5, 24
13	3	Additional tests for rewirable fixed socket-outlets with screwless terminals	5, 13.1, 11.10

* An additional new set of three samples prepared with the contacts closed is supplied by the manufacturer for this test.

NOTES:

1) *The order of tests given in sequence 1 is preferred but not mandatory except where required within the text of the appropriate clause.*

2) ***denotes that an additional three samples may be required for socket outlets incorporating electronic components.*

AMD 519

2) **Clause 12.21.1**

Add new clause as 12.21.1, immediately after clause 12.21 as follows :
Conformity shall be checked by inspection.

3) **Clause 12.27**

Add new clause as 12.27, immediately after the Notes given in clause 12.26 as follows :

12.27 Electronic components incorporated in socket outlets shall conform to Annex **H**

12.27.1 Conformity shall be checked by inspection of component conformity evidence and the tests of Annex **H**

4) **Clause 18.1.1**

Replace the nominal cross sectional area of the flexible cable 0.5 mm^2 given in first paragraph of clause 18.1.1a) with 1.0 mm^2
