

Amendment No. 1 Approved on 2019-05-08 to SLS 734: Part 4: 2017

SRI LANKA STANDARD SPECIFICATION FOR 13 A PLUGS, SOCKET-OUTLETS, ADAPTORS AND CONNECTION UNITS PART 4: SPECIFICATION FOR 13A FUSED CONNECTION UNITS SWITCHED AND UNSWITCHED

1) Replace the existing Table 1 with the following Table.

TABLE 1 : Schedule of tests.

Sequence (1)	Sample (2)	Tests (3)	Clause number (4)
1	3	Inspection, measurement and manipulation	5, 6, 7, 9, 11. 1 (except 11.9), 12 (12.1, 12.2, 12.3, 12.4 and 12.8), 18 (18.2 ,18.3 and 18.4 only), 8 (except Annex C), 20
2	3	General	5, 10, 18.1, 13.2, 12.5 (9.1.1 only), 19.1.3
3	3		5, 13.1, 14, 12.5(19.1.2 and 16.1.3 only), 16.1.2, 12.6, 15
4	3		5, 13.1, 14, 17
5	3	Materials	5, 21
6	3		5, 22.2, 8.2 (Annex C only)
7	3		5, 23
8 ^{A)}	3	Positive break	5, 12.7
9	3	Isolation	5, 14.2
10	3	Ingress protection	5, 12.9 and 12.10
11	3	Addition tests for Connection units with screwless terminals	5, 13.1, 11.9

NOTE: *The order of tests given in sequence 1 above is preferred but not mandatory except where required within the text of the appropriate clause.*

^{A)} An additional new set of three samples prepared with the contacts closed is supplied by the manufacturer for this test.
